



**NOTES:**


- 1) INSTALLING MOTORIZED VALVES ON EACH BOILER WILL VOID THE LOCK/TAKE WARRANTY. EMS WILL NOT INSTALL SAID VALVES. THE CHECK VALVE PROVIDED WILL STOP UNNECESSARY STANDBY FLOWS CAUSED BY THE OTHER BOILER IN OPERATION DURING A CALL.
- 2) A FLOW SWITCH WAS ERRONEOUSLY SUBMITTED IT WILL NOT BE USED IN THIS INSTALLATION. THE MANUFACTURER'S REP. HAS INDICATED IT BECOMES AN OPERATIONAL PROBLEM AND IS NOT NECESSARY FOR STAGING BOILERS.
- 3) BOILERS ARE ALTERNATING, NOT LEADLAG ONE BOILER WILL CARRY THE BUILDING LOAD BASED ON THE EXISTING PRIMARY PUMP GPM DELIVERY. EACH BOILER WILL MODULATE THE FIRING RATE BASED ON OUTDOOR TEMPERATURE AND SYSTEM WATER TEMPERATURE ALGORITHM.
- 4) THE PRIMARY PUMP(S) IN THE POLICE STATION ARE BELL AND GOSSETT (MODEL 80) RATED CAPACITY FOR EACH IS 46 GPM AT 28 FT. THE EXISTING GRUNDFOS MAGNA3 50-150 F PUMPS ARE SUFFICIENT IN SIZE TO CARRY THE ENT BUILDING LOAD WITHOUT CHANGE SEE SCHEDULE ON DRAWING M100.02
- 5) THE MAXIMUM FLOW PER BOILER IS 40 GPM AT A 30 DEGREE DELTA T. THIS WILL PRODUCE 600 MBH AS NEEDED. A 3" MAIN AND AIR SEPARATOR IS A MISMATCH TO THE EXISTING HYDRONIC DISTRIBUTION SYSTEM WHICH IS CURRENTLY 2". A 3" MAIN WILL NOT ALLOW SUFFICIENT VELOCITY TO MOVE ENTRAINED AIR FOR REMOVAL AT THE SEPARATOR THE FLOW RATE AT 40 GPM IS ONLY 1.6 FT/MIN. PROPER AIR REMOVAL VELOCITY SHOULD BE 3-4 FT/MIN. THEREFORE, WE HAVE MODELED A 2" HYDRONIC MAIN AS THIS ARRANGEMENT AT 40 GPM HAS A FLOW OF 3.9 FT/MIN. SUFFICIENT FOR GOOD SYSTEM AIR REMOVAL.
- 6) SINCE BID DOCUMENTS M-001 AND M-002 ARE AMBIGUOUS WITH RESPECT TO THE MANUFACTURER OF THE AIR SEPARATOR INDICATING SPRING VENT AND TACO, EMS CONCLUDES AN EQUAL IS AN ACCEPTABLE OPTION. THEREFORE, EMS IS SUBMITTING THE BELL & GOSSETT ITEM AS SCHEDULED ON M100.02.
- 7) NOTHING HAS BEEN INDICATED WITH RESPECT TO CONDENSATE REMOVAL DISCHARGE. EMS RECOMMENDS THE DISCHARGE BE PIPED TO THE LOCAL MOP SINK VIA A CONDENSATE PUMP SELECTED BY MARCHETTI CONSULTING ENGINEERS FOR THIS APPLICATION.
- 8) EMS RESERVES THE RIGHT TO USE PRO-PRESS FITTINGS ON THE HYDRONIC COPPER PIPING AS WELL AS SOLDERED FITTINGS. THE EXISTING HYDRONIC SYSTEM FEATURES PRO-PRESS JOINTS ALREADY.
- 9) EMS IS INSTALLING GALVANIZED SCH 40 WHEATLAND OR EQUAL MANUFACTURER'S ERW AS3 PIPING OUTSIDE WITH GALVANIZED MEGA-PRESS FITTINGS.
- 10) THE GAS METER IS INSUFFICIENTLY SIZED FOR THE BOILER LOAD ADDED TO THE BUILDING'S CURRENT GAS SUPPLY. METER TO BE UPGRADED TO HANDLE THE ADDED LOAD FOR THE BOILERS AND FOR THE FUTURE GENERATOR. EMS IS PROVIDING A 2" VALVED AND CAPPED CONNECTION NEAR THE PENETRATION INTO THE EMT GARAGE UNLESS DIRECTED OTHERWISE.
- 11) THE COMBUSTION AIR AND COMBUSTION EXHAUST PIPING HAS BEEN ROUTED TO THE ROOF IN ACCORDANCE WITH OWNER REQUEST / COMMENTS DURING WALK-THROUGH.




2) EXISTING MECH ROOM NORTH  
 3/4" = 1'-0"




4) EXISTING MECH ROOM EAST  
 3/4" = 1'-0"




5) EXISTING 3D



1) FIRST FLOOR MECHANICAL Existing  
 3/16" = 1'-0"



FIRST FLOOR MECHANICAL Existing -  
 6) Callout 1  
 1/2" = 1'-0"



3) EXISTING GAS METER  
 3/4" = 1'-0"

No.	Description	Date
1	SHOP DRAWING FOR REVIEW	5/24/2022

TOWN OF NEW CANAAN  
 EMS BUILDING BOILER PLAN  
 182 SOUTH AVE  
 NEW CANAAN, CT 06840

EXISTING DEMO PLAN


Project Number	5257
Date	5/12/2022
Drawn By	T.H.
Checked By	T.H.



**NOTES:**

- 1) INSTALLING MOTORIZED VALVES ON EACH BOILER WILL VOID THE LOCKHART WARRANTY. EMS WILL NOT INSTALL SHD VALVES. THE CHECK VALVE PROVIDED WILL STOP UNNECESSARY STANDBY FLOWS CAUSED BY THE OTHER BOILER IN OPERATION DURING A CALL.
- 2) A FLOW SWITCH WAS ERRONEOUSLY SUBMITTED. IT WILL NOT BE USED IN THIS INSTALLATION. THE MANUFACTURER'S REF. HAS INDICATED IT BECOMES AN OPERATIONAL PROBLEM AND IS NOT NECESSARY FOR STAGING BOILERS.
- 3) BOILERS ARE ARE ALTERNATING, NOT LEADLAG. ONE BOILER WILL CARRY THE BUILDING LOAD BASED ON THE EXISTING PRIMARY PUMP GPM DELIVERY. EACH BOILER WILL MODULATE THE FIRING RATE BASED ON OUTDOOR TEMPERATURE AND SYSTEM WATER TEMPERATURE ALGORITHM.
- 4) THE PRIMARY PUMP(S) IN THE POLICE STATION ARE BELL AND GOSSETT MODEL 30. RATED CAPACITY FOR EACH IS 46 GPM AT 28 FT. THE EXISTING GRUNDFOS MAGNA3 90-150 F PUMPS ARE SUFFICIENT IN SIZE TO CARRY THE ENT BUILDING LOAD WITHOUT CHANGE. SEE SCHEDULE ON DRAWING M100.02.
- 5) THE MAXIMUM FLOW PER BOILER IS 40 GPM AT A 30 DEGREE DELTA T. THIS WILL PRODUCE 600 MMH AS NEEDED. A 3" MAIN AND AIR SEPARATOR IS A MISMATCH TO THE EXISTING HYDRONIC DISTRIBUTION SYSTEM WHICH IS CURRENTLY 2". A 3" MAIN WILL NOT ALLOW SUFFICIENT VELOCITY TO MOVE ENTRAINED AIR FOR REMOVAL AT THE SEPARATOR. THE FLOW RATE AT 40 GPM IS ONLY 1.6 FT/MIN. PROPER AIR REMOVAL VELOCITY SHOULD BE 3-4 FT/MIN. THEREFORE, WE HAVE MODELED A 2" HYDRONIC MAIN AS THIS ARRANGEMENT. AT 40 GPM, HAS A FLOW OF 3.9 FT/MIN. SUFFICIENT FOR GOOD SYSTEM AIR REMOVAL.
- 6) SINCE BID DOCUMENTS M-001 AND M-002 ARE AMBIGUOUS WITH RESPECT TO THE MANUFACTURER OF THE AIR SEPARATOR INDICATING SPRO VENT AND TACO, EMS CONCLUDES AN EQUAL IS AN ACCEPTABLE OPTION. THEREFORE, EMS IS SUBMITTING THE BELL & GOSSETT ITEM AS SCHEDULED ON M100.02.
- 7) NOTHING HAS BEEN INDICATED WITH RESPECT TO CONDENSATE REMOVAL DISCHARGE. EMS RECOMMENDS THE DISCHARGE BE PIPED TO THE LOCAL MOP SINK VIA A CONDENSATE PUMP SELECTED BY MARSHETTI CONSULTING ENGINEERS FOR THE APPLICATION.
- 8) EMS RESERVES THE RIGHT TO USE PRO-PRESS FITTINGS ON THE HYDRONIC COPPER PIPING AS WELL AS SOLDERED FITTINGS. THE EXISTING HYDRONIC SYSTEM FEATURES PRO-PRESS JOINTS ALREADY.
- 9) EMS IS INSTALLING GALVANIZED SCH 40 WHEATLAND OR EQUAL MANUFACTURER'S ERW ADS PIPING OUTSIDE WITH GALVANIZED MEGA-PRESS FITTINGS.
- 10) THE GAS METER IS INSUFFICIENTLY SIZED FOR THE BOILER LOAD ADDED TO THE BUILDING'S CURRENT GAS SUPPLY. METER TO BE UPGRADED TO HANDLE THE ADDED LOAD FOR THE BOILERS AND FOR THE FUTURE GENERATOR. EMS IS PROVIDING A 2" VALVED AND CAPPED CONNECTION NEAR THE PENETRATION INTO THE EMT GARAGE UNLESS DIRECTED OTHERWISE.
- 11) THE COMBUSTION AIR AND COMBUSTION EXHAUST PIPING HAS BEEN ROUTED TO THE ROOF IN ACCORDANCE WITH OWNER REQUEST / COMMENTS DURING WALK-THROUGH.

MECHANICAL  
124



FIRST FLOOR MECHANICAL BOILER  
 1 PLAN  
 1" = 1'-0"

No.	Description	Date
1	SHOP DRAWING FOR REVIEW	5/24/2022

TOWN OF NEW CANAAN  
 EMS BUILDING BOILER PLAN







182 SOUTH AVE  
 NEW CANAAN, CT 06840

BOILER PLAN

Project Number	5257
Date	5/12/2022
Drawn By	T.H.
Checked By	T.H.

M100.01

- NOTES:**
- 1) INSTALLING MOTORIZED VALVES ON EACH BOILER WILL VOID THE LOCHINVAR WARRANTY. EMS WILL NOT INSTALL SAND VALVES. THE CHECK VALVE PROVIDED WILL STOP UNNECESSARY STANDBY FLOWS CAUSED BY THE OTHER BOILER IN OPERATION DURING A CALL.
  - 2) A FLOW SWITCH WAS ERRONEOUSLY SUBMITTED IT WILL NOT BE USED IN THIS INSTALLATION. THE MANUFACTURER'S REP. HAS INDICATED IT BECOMES AN OPERATIONAL PROBLEM AND IS NOT NECESSARY FOR STAGING BOILERS.
  - 3) BOILERS ARE ALTERNATING, NOT LEAD/LAG. ONE BOILER WILL CARRY THE BUILDING LOAD BASED ON THE EXISTING PRIMARY PUMP GPM DELIVERY. EACH BOILER WILL MODULATE THE FIRING RATE BASED ON OUTDOOR TEMPERATURE AND SYSTEM WATER TEMPERATURE ALGORITHM.
  - 4) THE PRIMARY PUMP(S) IN THE POLICE STATION ARE BELL AND GOSSETT MODEL 80. RATED CAPACITY FOR EACH IS 46 GPM AT 28 FT. THE EXISTING GRUNDFOS MAGNA3 50-150 F PUMPS ARE SUFFICIENT IN SIZE TO CARRY THE ENTIRE BUILDING LOAD WITHOUT CHANGE. SEE SCHEDULE ON DRAWING M100.02.
  - 5) THE MAXIMUM FLOW PER BOILER IS 40 GPM AT A 30 DEGREE DELTA T. THIS WILL PRODUCE 600 MMH AS NEEDED. A 3" MAIN AND AIR SEPARATOR IS A MISMATCH TO THE EXISTING HYDRONIC DISTRIBUTION SYSTEM WHICH IS CURRENTLY 2". A 3" MAIN WILL NOT ALLOW SUFFICIENT VELOCITY TO MOVE ENTRAINED AIR FOR REMOVAL AT THE SEPARATOR. THE FLOW RATE AT 40 GPM IS ONLY 1.6 FT/MIN. PROPER AIR REMOVAL VELOCITY SHOULD BE 3-4 FT/MIN. THEREFORE, WE HAVE MODELED A 2" HYDRONIC MAIN AS THIS ARRANGEMENT AT 40 GPM HAS A FLOW OF 3.8 FT/MIN. SUFFICIENT FOR GOOD SYSTEM AIR REMOVAL.
  - 6) SINCE BID DOCUMENTS M-01 AND M-02 ARE AMBIGUOUS WITH RESPECT TO THE MANUFACTURER OF THE AIR SEPARATOR INDICATING BRISQ VENT AND TACO, EMS CONCLUDES AN EQUAL IS AN ACCEPTABLE OPTION. THEREFORE, EMS IS SUBMITTING THE BELL & GOSSETT ITEM AS SCHEDULED ON M100.02.
  - 7) NOTHING HAS BEEN INDICATED WITH RESPECT TO CONDENSATE REMOVAL DISCHARGE. EMS RECOMMENDS THE DISCHARGE BE PIPED TO THE LOCAL MOP SINK VIA A CONDENSATE PUMP SELECTED BY MARCHETTI CONSULTING ENGINEERS FOR THIS APPLICATION.
  - 8) EMS RESERVES THE RIGHT TO USE PRO-PRESS FITTINGS ON THE HYDRONIC COPPER PIPING AS WELL AS SOLDERED FITTINGS. THE EXISTING HYDRONIC SYSTEM FEATURES PRO-PRESS JOINTS ALREADY.
  - 9) EMS IS INSTALLING GALVANIZED SCH 40 WHEATLAND OR EQUAL MANUFACTURER'S BRW ASS PIPING OUTSIDE WITH GALVANIZED MEGA-PRESS FITTINGS.
  - 10) THE GAS METER IS INSUFFICIENTLY SIZED FOR THE BOILER LOAD ADDED TO THE BUILDING'S CURRENT GAS SUPPLY. METERS TO BE UP-SIZED TO HANDLE THE ADDED LOAD FOR THE BOILERS AND FOR THE FUTURE GENERATOR. EMS IS PROVIDING A 2" VALVED AND CAPPED CONNECTION NEAR THE PENETRATION INTO THE EMT GARAGE UNLESS DIRECTED OTHERWISE.
  - 11) THE COMBUSTION AIR AND COMBUSTION EXHAUST PIPING HAS BEEN ROUTED TO THE ROOF IN ACCORDANCE WITH OWNER REQUEST / COMMENTS DURING WALK-THROUGH.



Mark	Manufacturer	Family and Type	Rated flow	Voltage	RatedPower
B1	Lochinvar	FTXL Boiler FTX400-850: FTX800			
P1 CIRC	BELL & GOSSETT A XYLEM BRAND	B&G PL-75 BL 035LF CIRC; B&G PL-75 BL 035LF CIRC	30 GPM @ 11 FT	115 V / 1 Phase / 60 Hz	241.5 watts
D60V EXP TANK	BELL & GOSSETT A XYLEM BRAND	BELL AND GOSSETT D-60V EXP TANK; ASME D60V EXP TANK			
B2	Lochinvar	FTXL Boiler FTX400-850: FTX800			
P2 CIRC	BELL & GOSSETT A XYLEM BRAND	B&G PL-75 BL 035LF CIRC; B&G PL-75 BL 035LF CIRC	30 GPM @ 11 FT	115 V / 1 Phase / 60 Hz	241.5 watts
P-3 (existing to remain)	Grundfos	GRUNDFOS MAGNA3; Grundfos Magna3 Pump	45.7 GPM @ 32 FT	1 x 115 Volt 1 Phase 60 Hz	18.5 to 643 Watts
P-4 (Existing to remain)	Grundfos	GRUNDFOS MAGNA3; Grundfos Magna3 Pump	45.7 GPM @ 32 FT	1 x 115 Volt 1 Phase 60 Hz	18.5 to 643 Watts
PLATE AND FRAME HX		Brazed_Plate_Heat_Exchanger_20309; Brazeed_Plate_Heat_Exchanger_20309			
TACO CIRCULATOR RADIANT	Taco	Pump-Circulator-Taco-LoadMatch-Flanged: L0205 - 1_0.025 HP_3250			
AGF	EMS AGF PARA: WATTS BFP AGF				
AXIOM GLYCOL PUMP / TANK (EXIST)		AXIOM SF100 GYLCOLE FEED TANK; AXIOM SF100			
AS-1	Bell & Gossett	BG_Rolairtrol Air Separator NPT With Strainer_R-N: 140	140 GPM		

Size	System Abbreviation	Length	Family and Type
1 1/2"ø	G	39' - 8 5/8"	Pipe Types: VIEGA MEGA PRESS CS GALV
1 1/4"ø	G	0' - 4 1/4"	Pipe Types: VIEGA MEGA PRESS CS GALV
1"ø	G	0' - 2 15/16"	Pipe Types: VIEGA MEGA PRESS CS GALV
2"ø	G	156' - 10 5/16"	Pipe Types: VIEGA MEGA PRESS CS GALV

Count	Size	System Abbreviation	Description
2	1 1/2"ø	G	CAPS
7	1 1/2"ø-1 1/2"ø	G	5 - 90 ELL / 2- UNIONS
2	1 1/2"ø-1 1/2"ø-1 1/2"ø	G	TEES
1	1 1/4"ø-1"ø	G	REDUCERS
1	1"ø-1"ø-1"ø	G	TEES
1	2"ø	G	CAPS
1	2"ø-1 1/2"ø	G	REDUCERS
1	2"ø-1 1/4"ø	G	REDUCERS
15	2"ø-2"ø	G	90 ELL
1	2"ø-2"ø-1 1/2"ø	G	TEES
1	2"ø-2"ø-2"ø	G	TEES

No.	Description	Date
1	SHOP DRAWING FOR REVIEW	5/24/2022

TOWN OF NEW CANAAN  
 EMS BUILDING BOILER PLAN

182 SOUTH AVE  
 NEW CANAAN, CT 06840

BOILER SECTIONS AND DETAILS


Project Number 5257  
 Date 5/12/2022  
 Drawn By T.H.  
 Checked By T.H.

M100.02

05/17/2022 12:07:09 PM

**NOTES:**

- 1) INSTALLING MOTORIZED VALVES ON EACH BOILER WILL VOID THE LOCKHART WARRANTY. EMS WILL NOT INSTALL SAID VALVES. THE CHECK VALVE PROVIDED WILL STOP UNNECESSARY STANDBY FLOWS CAUSED BY THE OTHER BOILER IN OPERATION DURING A CALL.
- 2) A FLOW SWITCH WAS ERRONEOUSLY SUBMITTED. IT WILL NOT BE USED IN THIS INSTALLATION. THE MANUFACTURER'S REP. HAS INDICATED IT BECOMES AN OPERATIONAL PROBLEM AND IS NOT NECESSARY FOR STAGING BOILERS.
- 3) BOILERS ARE ARE ALTERNATING, NOT LEADLAG. ONE BOILER WILL CARRY THE BUILDING LOAD BASED ON THE EXISTING PRIMARY PUMP GPM DELIVERY. EACH BOILER WILL MODULATE THE FIRING RATE BASED ON OUTDOOR TEMPERATURE AND SYSTEM WATER TEMPERATURE ALGORITHM.
- 4) THE PRIMARY PUMPS IN THE POLICE STATION ARE BELL AND GOSSETT MODEL 80. RATED CAPACITY FOR EACH IS 46 GPM AT 28 FT. THE EXISTING GRUNDOS MAGNA3 50-150 F PUMPS ARE SUFFICIENT IN SIZE TO CARRY THE EMT BUILDING LOAD WITHOUT CHANGE. SEE SCHEDULE ON DRAWING M100.02
- 5) THE MAXIMUM FLOW PER BOILER IS 40 GPM AT A 30 DEGREE DELTA T. THIS WILL PRODUCE 600 MMH AS NEEDED. A 3" MAIN AND AIR SEPARATOR IS A MISMATCH TO THE EXISTING HYDRONIC DISTRIBUTION SYSTEM WHICH IS CURRENTLY 2". A 3" MAIN WILL NOT ALLOW SUFFICIENT VELOCITY TO MOVE ENTRAINED AIR FOR REMOVAL AT THE SEPARATOR. THE FLOW RATE AT 40 GPM IS ONLY 1.6 FT/MIN. PROPER AIR REMOVAL VELOCITY SHOULD BE 3-4 FT/MIN. THEREFORE, WE HAVE MODELLED A 2" HYDRONIC MAIN AS THIS ARRANGEMENT. AT 40 GPM, HAS A FLOW OF 3.8 FT/MIN. SUFFICIENT FOR GOOD SYSTEM AIR REMOVAL.
- 6) SINCE BID DOCUMENTS M-001 AND M-002 ARE AMBIGUOUS WITH RESPECT TO THE MANUFACTURER OF THE AIR SEPARATOR INDICATING SPRO VENT AND TACO, EMS CONCLUDES AN EQUAL IS AN ACCEPTABLE OPTION. THEREFORE, EMS IS SUBMITTING THE BELL & GOSSETT ITEM AS SCHEDULED ON M100.02.
- 7) NOTHING HAS BEEN INDICATED WITH RESPECT TO CONDENSATE REMOVAL DISCHARGE. EMS RECOMMENDS THE DISCHARGE BE PIPED TO THE LOCAL MOP SINK VIA A CONDENSATE PUMP SELECTED BY MARCHETTI CONSULTING ENGINEERS FOR THIS APPLICATION.
- 8) EMS RESERVES THE RIGHT TO USE PRO-PRESS FITTINGS ON THE HYDRONIC COPPER PIPING AS WELL AS SOLDERED FITTINGS. THE EXISTING HYDRONIC SYSTEM FEATURES PRO-PRESS JOINTS ALREADY.
- 9) EMS IS INSTALLING GALVANIZED SCH 40 WHEATLAND OR EQUAL MANUFACTURER'S DRW ASS PIPING OUTSIDE WITH GALVANIZED MEGA-PRESS FITTINGS.
- 10) THE GAS METER IS INSUFFICIENTLY SIZED FOR THE BOILER LOAD ADDED TO THE BUILDING'S CURRENT GAS SUPPLY. METER TO BE UP-SIZED TO HANDLE THE ADDED LOAD FOR THE BOILERS AND FOR THE FUTURE GENERATOR. EMS IS PROVIDING A 2" VALVED AND CAPPED CONNECTION NEAR THE PENETRATION INTO THE EMT GARAGE UNLESS DIRECTED OTHERWISE.
- 11) THE COMBUSTION AIR AND COMBUSTION EXHAUST PIPING HAS BEEN NOTED TO THE ROOF IN ACCORDANCE WITH OWNER REQUEST / COMMENTS DURING WALK-THROUGH.



No.	Description	Date
1	SHOP DRAWING FOR REVIEW	5/24/2022

TOWN OF NEW CANAAN  
 EMS BUILDING BOILER PLAN  
 182 SOUTH AVE  
 NEW CANAAN, CT 06840

**BOILER PLAN ISO**

Project Number	5257
Date	5/12/2022
Drawn By	T.H.
Checked By	T.H.

**M100.03**